



CATCH BASIN SIZE	OUTLET PIPE SIZE
2-2	12" OR SMALLER
2-3	12" TO 33"

SECTION C-C

SECTION B-B

SECTION A-A

GRATING—SHALL BE EAST JORDAN FRAME & GRATE NO. *5111-B OR NEENAH GRATE R-4859 WITH FRAME R-4899 OR EQUAL. ALL OPENINGS ON GRATES SHALL BE 10 INCHES OR LESS IN LENGTH.

APPROVED RED BRICK OR CAST-IN-PLACE WALLS SHALL HAVE A NOMINAL THICKNESS OF 8 INCHES, PRE-CAST WALLS SHALL HAVE A MINIMUM THICKNESS OF 6 INCHES AND BE REINFORCED SUFFICIENTLY TO PERMIT SHIPPING AND HANDLING WITHOUT DAMAGE.

OPENING FOR PIPES SHALL BE O.D. = 2" WHEN PREFABRICATED OR FIELD CUT.
 STEPS SHALL BE PROVIDED WHERE THE DEPTH EXCEEDS 36" AND SHALL BE ALUMINUM OR PLASTIC COATED CAST IRON NEENAH 1980-C OR EQUAL.

CONCRETE, CAST-IN-PLACE TO BE CLASS C 5 1/2 SACK.

NOT TO SCALE