



NOT TO SCALE

NOTES:

1. FOR MANHOLE SPECS AND REQUIREMENTS, SEE TYPICAL SANITARY PRECAST MANHOLE DETAIL.
2. IF DROP MANHOLE IS INSTALLED DURING NEW CONSTRUCTION, MANHOLE SHALL BE 6 FT. IN DIAMETER AND SHALL HAVE A FACTORY INSTALLED SEAL FOR THE DROP PIPE.
3. FASTEN TREATED HARD WOOD BLOCKING BEHIND PIPE AND INSTALL STAINLESS STEEL STRAPPING AND ANCHORS AT TOP AND BOTTOM OF VERTICAL PIPE.
4. IF STAIRS INTERFERE WITH DROP, THEY SHALL BE REMOVED AND REDRILLED IN A LOCATION THAT IS STILL EASILY ACCESSIBLE FOR ENTERING MANHOLE.