



NOT TO SCALE

NOTES:

1. ALL 100 YR. OVERFLOW SIDEWALKS SHALL BE INSTALLED BY DEVELOPER AND ACCEPTED BY THE CITY OF WADSWORTH PRIOR TO FINAL PLAT APPROVAL.
2. DOUBLE INLET BASINS SHALL BE INSTALLED AT LOW POINT AND CURB SHALL BE DROPPED 1.5 FT. AWAY ON EITHER SIDE OF THE INLETS.
3. A 2 FT. BY 2 FT. BASIN SHALL BE INSTALLED DOWNSTREAM OF THE DOUBLE INLETS AND THE DROP CURB SWALE SHALL BE ORIENTED TOWARDS THAT BASIN.
4. DOWNSTREAM CHANNEL SHALL BE SIZED TO ACCOMMODATE A 100 YR. STORM.
5. POSITIVE DRAINAGE OF 1% MIN. SHALL BE MAINTAINED FROM 100 YR. SIDEWALK TO DOWNSTREAM SWALE OR TO CATCH BASIN IN SWALE.